

Environmental Protection Agency

§ 406.34

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
	Metric units (kilograms per 1,000 kg of corn)	
BOD ₅	0.11	0.036
TSS	0.054	0.18
pH	(¹)	(¹)
	English units (pounds per 1,000 stbu of corn)	
BOD ₅	6.0	2.0
TSS	3.0	1.0
pH	(¹)	(¹)

¹ Within the range 6.0 to 9.0.

§ 406.26 Pretreatment standards for new sources.

Any new source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403.

[60 FR 33936, June 29, 1995]

§ 406.27 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 406.22 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

Subpart C—Normal Wheat Flour Milling Subcategory

§ 406.30 Applicability; description of the normal wheat flour milling subcategory.

The provisions of this subpart are applicable to discharges resulting from the processes in which wheat and other

grains are milled by dry processes into flour and millfeed.

§ 406.31 Specialized definitions.

For the purpose of this subpart:

(a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.

§ 406.32 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT): There shall be no discharge of process waste water pollutants to navigable waters.

[60 FR 33936, June 29, 1995]

§ 406.33 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best available technology economically achievable.

The following limitations establish the quantity or quality of pollutants or pollutant properties which may be discharged by a point source subject to the provisions of this subpart after application of the best available technology economically achievable: there shall be no discharge of process waste water pollutants to navigable waters.

§ 406.34 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or pollutant properties controlled by this section which may be discharged to a publicly owned treatment works by a point source subject to the provisions of this subpart.